



Bulk Asbestos Analysis

(EPA Method 40CFR, Part 763, Appendix E to Subpart E and EPA 600/R-93-116, Visual Area Estimation)
NVLAP Lab Code:

Sample Company
Sample Contact
000 Sample Street
Suite 000
Sample City, CA 00000

Client ID: 0000
Report Number: B000000
Date Received: 00/00/0000
Date Analyzed: 00/00/0000
Date Printed: 00/00/0000
First Reported: 00/00/0000

Job ID/Site: Sample Site

SGSFL Job ID: 0000-0

Date(s) Collected: 00/00/0000

Total Samples Submitted: 4
Total Samples Analyzed: 4

Sample ID	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
1 Layer: White Tape Layer: White Joint Compound Layer: Paint	00000000		ND				
			ND				
			ND				
		Total Composite Values of Fibrous Components: Cellulose (5 %)	Asbestos (ND)				
2 Layer: White Tape Layer: White Joint Compound Layer: Paint	00000000		ND				
			ND				
			ND				
		Total Composite Values of Fibrous Components: Cellulose (5 %)	Asbestos (ND)				
3 Layer: Brown Sheet Flooring Layer: Fibrous Backing Layer: Yellow Mastic	00000000		ND				
			70 %	Chrysotile			
			ND				
		Total Composite Values of Fibrous Components: Cellulose (5 %)	Asbestos (25%)				
4 Layer: Brown Sheet Flooring Layer: Fibrous Backing Layer: Yellow Mastic	00000000		ND				
			70 %	Chrysotile			
			ND				
		Total Composite Values of Fibrous Components: Cellulose (5 %)	Asbestos (25%)				

Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by SGS Forensic Laboratories (SGSFL) at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by SGSFL to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by SGSFL. The client is solely responsible for the use and interpretation of test results and reports requested from SGSFL. SGS Forensic Laboratories is not able to assess the degree of hazard resulting from materials analyzed. SGSFL reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.